



CE TEST REPORT

according to

**European Standard EN 55022:1998 Class B,
EN 61000-3-2: 2000, EN 61000-3-3:1995 and EN 55024:1998
(IEC 61000-4-2:1995, IEC 61000-4-3:1995, IEC 61000-4-4:1995,
IEC 61000-4-5:1995, IEC 61000-4-6:1996, IEC 61000-4-8:1993,
IEC 61000-4-11:1994)**

Equipment : Switching Power Supply

Model No. : SPU45E-XXX (X=0~9)

Applicant : **SINPRO Electronic Co., Ltd.**
2F, No. 2, East Sec., Kung Yeh 6th Rd., Pingtung City,
Pingtung County, Taiwan, R.O.C.

- The test result refers exclusively to the test presented test model / sample.
- Without written approval of SPORTON International Inc., the test report shall not be reproduced except in full.
- This test report is only applicable to European Community.

SPORTON International Inc.

6F, No. 106, Sec. 1, Hsin Tai Wu Rd., Hsi Chih, Taipei Hsien, Taiwan, R.O.C.

Table of Contents

History of this test report	iii
CERTIFICATE OF COMPLIANCE.....	1
1. General Description of Equipment under Test.....	2
1.1 Applicant.....	2
1.2 Manufacturer	2
1.3 Basic Description of Equipment under Test	2
1.4 Feature of Equipment under Test	2
2. Test Configuration of Equipment under Test.....	4
2.1 Test Manner	4
2.2 Description of Test System	4
3. Test Software	4
4. General Information of Test.....	6
4.1 Test Facility	6
4.2 Standard for Methods of Measurement.....	6
4.3 Test in Compliance with	6
4.4 Frequency Range Investigated	6
4.5 Test Distance	6
5. Test of Conducted Powerline	7
5.1 Description of Major Test Instruments	7
5.2 Test Procedures.....	8
5.3 Typical Test Setup Layout of Conducted Powerline	9
5.4 Test Result of AC Powerline Conducted Emission	10
5.5 Photographs of Conducted Powerline Test Configuration	11
6. Test of Radiated Emission.....	12
6.1 Description of Major Test Instruments	12
6.2 Test Procedures.....	13
6.3 Typical Test Setup Layout of Radiated Emission.....	14
6.4 Test Result of Radiated Emission	15
6.5 Photographs of Radiated Emission Test Configuration	16
7. Harmonics Test.....	17
7.1 Standard.....	17
7.2 Test Procedure.....	17
7.3 Test Equipment Settings	17
7.4 Test Setup	17
7.5 Current Harmonics Test	18
8. Voltage Fluctuations Test.....	19
8.1 Standard.....	19
8.2 Test Procedure.....	19
8.3 Test Equipment Settings	19
8.4 Test Setup	19
8.5 Test Result Of Voltage Fluctuation And Flicker Test	20
8.6 Photographs Of Harmonics Test, Voltage Fluctuation And Flicker Test	21
9. Electrostatic Discharge Immunity Test (ESD)	22
9.1 Test setup.....	22
9.2 Test Setup for Tests Performed in Laboratory	23
9.3 ESD Test Procedure	24

9.4 Test Severity Levels	25
9.5 Test Points	26
9.6 Photographs of Electrostatic Discharge Immunity Test	28
10. Radio Frequency Electromagnetic Field Immunity Test (RS).....	29
10.1 Test setup.....	29
10.2 Test Procedure	30
10.3 Test Severity Levels	30
10.4 Photographs of Radio Frequency Electromagnetic Field Immunity Test	31
11. Electrical Fast Transient/Burst Immunity Test (EFT/BURST)	32
11.1 Test setup.....	32
11.2 Test on Power Line	33
11.3 Test on Communication Lines.....	33
11.4 Test Procedure	34
11.5 Test Severity Levels	35
11.6 Photographs of Electrical Fast Transient/Burst Immunity Test	36
12. Surge Immunity Test	37
12.1 Test Record	37
12.2 Test Level	38
12.3 Test Procedure	38
12.4 Operating Condition	39
12.5 Photographs of Surge Immunity Test.....	40
13. Conducted Disturbances Induced by Radio-Frequency Field Immunity Test (CS).....	41
13.1 Test Level.....	41
13.2 Operating Condition	41
13.3 Test Procedure	42
13.4 Photographs of Conducted Disturbances Induced by Radio-Frequency Field Immunity Test.....	43
14. Power Frequency Magnetic Field immunity tests	44
14.1 Test Record	44
14.2 Test Setup	44
14.3 Photographs of Power Frequency Magnetic Field immunity tests	45
15. Voltage Dips and Voltage Interruption Immunity Tests	46
15.1 Test Record of Voltage Interruption	46
15.2 Test Record of Voltage Dips	46
15.3 Testing Requirement and Procedure	47
15.4 Test Conditions	47
15.5 Operating Condition	47
15.6 Photographs of Voltage Dips and Voltage Interruption Immunity Tests.....	48
16. Antenna Factor & Cable Loss	49
17. List of Measuring Equipment Used	50
18. Notice for Class A Product	52
19. Declaration of Conformity and the CE Mark	53
Appendix A. Photographs of EUT.....	A1 ~ A7



History of this test report

Original Report Issue Date: May 11, 2002

☒ No additional attachment.

☐ Additional attachment were issued as following record:

Attachment No.	Issue Date	Description



CERTIFICATE OF COMPLIANCE

according to

**European Standard EN 55022:1998 Class B,
EN 61000-3-2: 2000, EN 61000-3-3:1995 and EN 55024:1998
(IEC 61000-4-2:1995, IEC 61000-4-3:1995, IEC 61000-4-4:1995,
IEC 61000-4-5:1995, IEC 61000-4-6:1996, IEC 61000-4-8:1993,
IEC 61000-4-11:1994)**

Equipment : Switching Power Supply

Model No. : SPU45E-XXX (X=0~9)


Applicant : **SINPRO Electronic Co., Ltd.**
2F, No. 2, East Sec., Kung Yeh 6th Rd., Pingtung City,
Pingtung County, Taiwan, R.O.C.

I HEREBY CERTIFY THAT :

The measurements shown in this test report were made in accordance with the procedures given in **EUROPEAN COUNCIL DIRECTIVE 89/336/EEC**. The equipment was **passed** the test performed according to **European Standard EN 55022:1998 Class B,**

EN 61000-3-2:2000, EN 61000-3-3:1995 and EN 55024:1998 (IEC 61000-4-2:1995, IEC 61000-4-3:1995, IEC 61000-4-4:1995, IEC 61000-4-5:1995, IEC 61000-4-6:1996, IEC 61000-4-8:1993, IEC 61000-4-11:1994).

The test was carried out on May 08, 2002 at **SPORTON International Inc.** LAB.


K. J. Lin
Manager

SPORTON International Inc.

6F, No. 106, Sec. 1, Hsin Tai Wu Rd., Hsi Chih, Taipei Hsien, Taiwan, R.O.C.

1. General Description of Equipment under Test

1.1 Applicant

SINPRO Electronic Co., Ltd.

2F, No. 2, East Sec., Kung Yeh 6th Rd., Pingtung City,
Pingtung County, Taiwan, R.O.C.

1.2 Manufacturer

Same as 1.1.

1.3 Basic Description of Equipment under Test

Equipment : Switching Power Supply
Model No : SPU45E-XXX (X=0~9)
Trade Name : SINPRO
Power Supply Type : Switching
AC Power Input : Non-Shielded, 1.8m, 3pin
DC Power Cable : Non-Shielded, 1.2m, 6pin

1.4 Feature of Equipment under Test

Output Voltage And Current Rating Chart (Single Output) :

Model Number	Output Voltage	Output Current	Maximum Output Power
SPU45E-100	2 ~ 3 VDC	8.00 A (Max.)	24W
SPU45E-101	3 ~ 5 VDC	8.00 A (Max.)	40W
SPU45E-102	5 ~ 6 VDC	8.00 ~ 6.66 A	40W
SPU45E-103	6 ~ 8 VDC	7.00 ~ 5.25 A	42W
SPU45E-104	8 ~ 11 VDC	5.63 ~ 4.00 A	45W
SPU45E-105	11 ~ 13 VDC	4.00 ~ 3.46 A	45W
SPU45E-106	13 ~ 16 VDC	3.46 ~ 2.81 A	45W
SPU45E-107	16 ~ 21 VDC	3.12 ~ 2.38 A	50W
SPU45E-108	21 ~ 27 VDC	2.30 ~ 1.85 A	50W
SPU45E-109	27 ~ 33 VDC	1.85 ~ 1.51 A	50W
SPU45E-110	33 ~ 40 VDC	1.51 ~ 1.25 A	50W
SPU45E-111	40 ~ 50 VDC	1.25 ~ 1.00 A	50W

Output Voltage And Current Rating Chart (Multi Output) :

Model Number	Output #1			Output #2			Output #3			Maximum Output Power
	Vonom	Iomin	Iomax	Vonom	Iomin	Iomax	Vonom	Iomin	Iomax	
SPU45E-200	+3.3V	0.7A	5.0 A	+12V	0.4A	2.0A				40 W
SPU45E-201	+5V	0.5A	5.0 A	+12V	0.2A	2.0A				42 W
SPU45E-202	+5V	0.5A	5.0 A	+15V	0.2A	1.5A				42 W
SPU45E-203	+5V	0.5A	5.0 A	+24V	0.1A	1.0A				42 W
SPU45E-204	+3.3V	0.7A	5.0 A	+5V	0.4A	2.0A				26.5 W
SPU45E-209	+12V	0.5A	3.0 A	-12V	0.2A	1.0A				42 W
SPU45E-210	+15V	0.5A	2.0 A	-15V	0.2A	1.0A				42 W
SPU45E-215	+5V	0.5A	5.0 A	-24V	0.1A	1.0A				42 W
SPU45E-216	+5.1V	0.0A	1.0 A	+7.2V	0.2A	2.6A				23.82 W
SPU45E-300	+3.3V	0.5A	5.0 A	+12V	0.2A	2.0A	-12V	0.16 A	0.8 A	42 W
SPU45E-301	+5V	0.5A	5.0 A	+12V	0.2A	2.0A	-5V	0.16 A	0.8 A	42 W
SPU45E-302	+5V	0.5A	5.0 A	+12V	0.2A	2.0A	-12V	0.16 A	0.8 A	42 W
SPU45E-303	+5V	0.5A	5.0 A	+15V	0.2A	2.0A	-15V	0.16 A	0.8 A	42 W
SPU45E-304	+5V	0.5A	5.0 A	+24V	0.1A	1.0A	-24V	0.1 A	0.5 A	42 W
SPU45E-305	+5V	0.5A	5.0 A	+24V	0.1A	1.0A	-12V	0.16 A	0.8 A	42 W
SPU45E-306	+3.3V	0.5A	5.0 A	+12V	0.2A	2.0A	-5V	0.16 A	0.8 A	42 W

2. Test Configuration of Equipment under Test

2.1 Test Manner

- a. During testing, the interface cables and equipment positions were varied according to European Standard EN55022.
- b. The complete test system included SINPRO Dummy Load and EUT for EMI test.
- c. The complete test system included BROTHER Multi-meter, SINPRO Dummy Load and EUT for EMS test.
- d. The EUT and Dummy Load were placed in one metal enclosure.
- e. Test Mode : SPU45E-302
- f. Frequency range investigated: conduction 150 KHz to 30 MHz, radiation 30 MHz to 1000MHz.

2.2 Description of Test System

< EMI >

Support Unit 1. -- Dummy Load (SINPRO)

Model No.	: N/A
Serial No.	: SP0100
Spec.	: 1.0Ω
	: 12Ω
	: 28.8Ω

< EMS >

Support Unit 1. -- Multi-meter (BROTHER)

Model No.	: YH-370A
Serial No.	: SP1077

Support Unit 2. -- Dummy Load (SINPRO)

Model No.	: N/A
Serial No.	: SP0100
Spec.	: 1.0Ω
	: 12Ω
	: 28.8Ω

3. Test Software

No test software was used during testing.

4. General Information of Test

4.1 Test Facility

< EMI >

This test was carried out by SPORTON International Inc.

Test Site Location : No. 30-2, Lin 6, Diing-Fwu Tsuen, Lin-Kou-Hsiang,
Taipei Hsien, Taiwan, R.O.C.
TEL : 886-2-2601-1640
FAX : 886-2-2601-1695

Test Site No. : CL01, OL05

< EMS >

This test was carried out by SPORTON International Inc.

Test Site Location : No. 52, Hwa Ya 1st Rd., Hwa Ya Technology Park,
Kwei-Shan Hsiang, Tao Yuan Hsien, Taiwan, R.O.C.
TEL : 886-3-327-3456
FAX : 886-3-318-0055

4.2 Standard for Methods of Measurement

EMI Test (conduction and radiation) : European Standard EN 55022 Class B

Harmonics Test : European Standard EN 61000-3-2.

Voltage Fluctuations Test : European Standard EN 61000-3-3.

EMS Test : European Standard EN 55024:1998.

(ESD: IEC 61000-4-2, RS: IEC 61000-4-3, EFT: IEC 61000-4-4, SURGE: IEC 61000-4-5,

CS: IEC 61000-4-6, Power Frequency Magnetic Field: IEC 61000-4-8, DIPS: IEC 61000-4-11)

4.3 Test in Compliance with

EMI Test (conduction and radiation) : European Standard EN 55022 Class B

Harmonics Test : European Standard EN 61000-3-2.

Voltage Fluctuations Test : European Standard EN 61000-3-3.

EMS Test : European Standard EN 55024:1998.

(ESD: IEC 61000-4-2, RS: IEC 61000-4-3, EFT: IEC 61000-4-4, SURGE: IEC 61000-4-5,

CS: IEC 61000-4-6, Power Frequency Magnetic Field: IEC 61000-4-8, DIPS: IEC 61000-4-11)

4.4 Frequency Range Investigated

a. Conducted emission test: from 150 kHz to 30 MHz

b. Radiated emission test: from 30 MHz to 1,000 MHz

c. Radio frequency electromagnetic field immunity test : 80-1000 MHz.

4.5 Test Distance

The test distance of radiated emission test from antenna to EUT is 10 M.

The test distance of radio frequency electromagnetic field immunity test from antenna to EUT is 3 M.



5. Test of Conducted Powerline

Conducted Emissions were measured from 150 kHz to 30 MHz with a bandwidth of 9 kHz on the 230VAC power and return leads of the EUT according to the methods defined in European Standard EN 55022 Clause 9. The EUT was placed on a nonmetallic stand in a shielded room 0.8 meters above the ground plane as shown in section 5.3. The interface cables and equipment positioning were varied within limits of reasonable applications to determine the position producing maximum conducted emissions.

5.1 Description of Major Test Instruments


- Test Receiver (HP 8591EM)
 - Attenuation 10 dB
 - Start Frequency 0.15 MHz
 - Stop Frequency 30 MHz
 - IF Bandwidth 9 KHz



5.2 Test Procedures

- a. The EUT was placed on a desk 0.8 meters height from the metal ground plane and 0.4 meter from the conducting wall of the shielding room and it was kept at least 0.8 meters from any other grounded conducting surface.
- b. Connect EUT to the power mains through a line impedance stabilization network (LISN).
- c. All the support units are connect to the other LISN.
- d. The LISN provides 50 ohm coupling impedance for the measuring instrument.
- e. The CISPR states that a 50 ohm , 50 microhenry LISN should be used.
- f. Both sides of AC line were checked for maximum conducted interference.
- g. The frequency range from 150 kHz to 30 MHz was searched.
- h. Set the test-receiver system to Peak Detect Function and Specified Bandwidth with Maximum Hold Mode.
- i. If the emission level of the EUT in peak mode was 6 dB lower than the limit specified, then testing will be stopped and peak values of EUT will be reported, otherwise, the emissions which do not have 6 dB margin will be retested one by one using the quasi-peak method and/or average methods and reported.

5.3 Typical Test Setup Layout of Conducted Powerline



5.4 Test Result of AC Powerline Conducted Emission

- Frequency Range of Test : from 0.15 MHz to 30 MHz
- Temperature : 25°C
- Relative Humidity : 50%
- Test Date : Apr. 30, 2002
- Test Mode : **Full Load**
- All emissions not reported here are more than 10 dB below the prescribed limit.

The Conducted Emission test was passed at minimum margin Line 0.190 MHz / 49.40 dBuV.

Frequency (MHz)	Line or Neutral	Meter Reading				Limits				Margin	
		Q.P. (dBuV)	A.V. (dBuV)	Q.P. (uV)	A.V. (uV)	Q.P. (dBuV)	A.V. (dBuV)	Q.P. (uV)	A.V. (uV)	Q.P. (dB)	A.V. (dB)
0.190	Line	50.00	49.40	316.23	295.12	64.04	54.04	1591.58	503.30	-14.04	-4.64
0.285	Line	39.80	39.00	97.72	89.13	60.67	50.67	1080.05	341.54	-20.87	-11.67
0.568	Line	33.80	32.60	48.98	42.66	56.00	46.00	630.96	199.53	-22.20	-13.40
0.188	Neutral	49.30	48.70	291.74	272.27	64.12	54.12	1607.77	508.42	-14.82	-5.42
0.284	Neutral	40.00	39.20	100.00	91.20	60.70	50.70	1083.69	342.69	-20.70	-11.50
4.152	Neutral	37.10	36.50	71.61	66.83	56.00	46.00	630.96	199.53	-18.90	-9.50

Test Engineer : Jason
Jason Chang

5.5 Photographs of Couducted Powerline Test Configuration

- The photographs show the configuration that generates the maximum emission.

FRONT VIEW



REAR VIEW



6. Test of Radiated Emission

Radiated emissions from 30 MHz to 1000 MHz were measured with a bandwidth of 120 kHz according to the methods defines in European Standard EN 55022, Clause 10. The EUT was placed on a nonmetallic stand in the open-field site, 0.8 meter above the ground plane, as shown in section 6.3. The interface cables and equipment positions were varied within limits of reasonable applications to determine the positions producing maximum radiated emissions.

6.1 Description of Major Test Instruments

- Amplifier (HP 8447D)
 - Attenuation 10 dB
 - RF Gain 25 dB
 - Signal Input 0.1 MHz to 1.3 GHz


- Spectrum Analyzer (ADVANTEST R3261C)
 - Attenuation 10 dB
 - Start Frequency 30 MHz
 - Stop Frequency 1000 MHz
 - Resolution Bandwidth 1 MHz
 - Video Bandwidth 1 MHz
 - Signal Input 100 Hz to 1.5 GHz



6.2 Test Procedures

- a. The EUT was placed on a rotatable table top 0.8 meter above ground.
- b. The EUT was set 10 meters from the interference-receiving antenna which was mounted on the top of a variable height antenna tower.
- c. The table was rotated 360 degrees to determine the position of the highest radiation.
- d. The antenna is a half wave dipole and its height is varied between one meter and four meters above ground to find the maximum value of the field strength both horizontal polarization and vertical polarization of the antenna are set to make the measurement.
- e. For each suspected emission the EUT was arranged to its worst case and then tune the antenna tower (from 1 M to 4 M) and turn table (from 0 degree to 360 degrees) to find the maximum reading.
- f. Set the test-receiver system to Peak Detect Function and specified bandwidth with Maximum Hold Mode.
- g. If the emission level of the EUT in peak mode was 6 dB lower than the limit specified, then testing will be stopped and peak values of EUT will be reported, otherwise, the emissions which do not have 6 dB margin will be repeated one by one using the quasi-peak method and reported.

6.3 Typical Test Setup Layout of Radiated Emission




6.4 Test Result of Radiated Emission

- Frequency Range of Test : from 30 MHz to 1000 MHz
- Test Distance : 10 M
- Temperature : 33.°C
- Relative Humidity : 57%
- Test Date : Apr. 30, 2002
- Test Mode : **Full Load**
- Emission level (dBuV/m) = 20 log Emission level (uV/m)
- Corrected Reading : Antenna Factor + Cable Loss + Reading = Emission

The Radiated Emission test was passed at minimum margin:

Vertical **46.300 MHz / 24.49 dBuV/m** Antenna Height **1.0** Meter, Turntable Degree **0 °**.

Frequency (MHz)	Polarity	Antenna Factor (dB/m)	Cable Loss (dB)	Reading (dBuV)	Limits (dBuV/m) (uV/m)	Emission (dBuV/m)	Level (uV/m)	Margin (dB)
44.500	H	10.39	0.90	5.70	30.00 32	16.99	7.07	-13.01
141.000	H	11.33	1.51	4.66	30.00 32	17.50	7.50	-12.50
46.300	V	9.38	0.91	14.20	30.00 32	24.49	16.77	-5.51
72.300	V	6.65	1.37	14.84	30.00 32	22.86	13.90	-7.14
83.700	V	8.32	1.16	10.07	30.00 32	19.55	25.71	-10.45
140.300	V	11.33	1.51	8.96	30.00 32	21.80	24.83	-8.20

Test Engineer : 
Jackson Huang

6.5 Photographs of Radiated Emission Test Configuration

- The photographs show the configuration that generates the maximum emission.

FRONT VIEW



REAR VIEW



7. Harmonics Test

7.1 Standard

- Standard : EN 61000-3-2:2000


7.2 Test Procedure

The measured values of the harmonics components of the input current, including line current and neutral current, shall be compared with the limits given in Clause 7 of EN 61000-3-2.

7.3 Test Equipment Settings

- Line Voltage : 230 V
- Line Frequency : 50 Hz
- Device Class : D
- Current Measurement Range : High
- Measurement Delay : 10.0 seconds
- Test Duration : 2.00 minutes
- Class determination Pre-test Duration : 10.00 seconds

7.4 Test Setup



7.5 Current Harmonics Test

7.5.1 Test Data Of Current Harmonics

- FINAL TEST RESULT : **PASS**
- Fundamental Current : 0.500 A
- Real Power : 52.03 W
- Power Factor : 0.453
- Temperature : 23°C
- Relative Humidity : 48%
- Test Date : May 08, 2002
- Test Mode : **Full Load**

Order	Freq. [Hz]	Iavg [A]	Iavg%L [%]	Imax [A]	Imax%L [%]	Limit [A]
1	50	0.2292		0.2301		
2	100	0.0000	0.0000	0.0012	0.1130	1.0800
3	150	0.2179	9.4737	0.2191	9.5268	2.3000
4	200	0.0000	0.0000	0.0012	0.2839	0.4300
5	250	0.2066	18.123	0.2075	18.203	1.1400
6	300	0.0000	0.0000	0.0015	0.5086	0.3000
7	350	0.1892	24.573	0.1901	24.691	0.7700
8	400	0.0000	0.0000	0.0015	0.6634	0.2300
9	450	0.1678	41.962	0.1688	42.191	0.4000
10	500	0.0000	0.0000	0.0015	0.8293	0.1840
11	550	0.1431	43.372	0.1447	43.834	0.3300
12	600	0.0000	0.0000	0.0015	0.9951	0.1533
13	650	0.1172	55.804	0.1190	56.676	0.2100
14	700	0.0000	0.0000	0.0015	1.1610	0.1314
15	750	0.0916	61.035	0.0934	62.256	0.1500
16	800	0.0000	0.0000	0.0012	1.0615	0.1150
17	850	0.0677	51.188	0.0693	52.341	0.1324
18	900	0.0000	0.0000	0.0009	0.8956	0.1022
19	950	0.0464	39.171	0.0479	40.460	0.1184
20	1000	0.0000	0.0000	0.0009	0.9951	0.0920
21	1050	0.0296	27.629	0.0308	28.768	0.1071
22	1100	0.0000	0.0000	0.0006	0.7298	0.0836
23	1150	0.0189	19.341	0.0195	19.965	0.0978
24	1200	0.0000	0.0000	0.0003	0.3981	0.0767
25	1250	0.0159	17.632	0.0162	17.971	0.0900
26	1300	0.0000	0.0000	0.0003	0.4312	0.0708
27	1350	0.0174	20.874	0.0174	20.874	0.0833
28	1400	0.0000	0.0000	0.0003	0.4644	0.0657
29	1450	0.0183	23.600	0.0186	23.994	0.0776
30	1500	0.0000	0.0000	0.0006	0.9951	0.0613
31	1550	0.0180	24.807	0.0183	25.228	0.0726
32	1600	0.0000	0.0000	0.0006	1.0615	0.0575
33	1650	0.0156	22.827	0.0162	23.722	0.0682
34	1700	0.0000	0.0000	0.0006	1.1278	0.0541
35	1750	0.0125	19.463	0.0131	20.413	0.0643
36	1800	0.0000	0.0000	0.0006	1.1942	0.0511
37	1850	0.0085	14.052	0.0092	15.055	0.0608
38	1900	0.0000	0.0000	0.0003	0.6303	0.0484
39	1950	0.0052	8.9925	0.0055	9.5215	0.0577
40	2000	0.0000	0.0000	0.0003	0.6634	0.0460

Test Engineer : Bruce
Bruce Huang

8. Voltage Fluctuations Test

8.1 Standard

- Standard : EN 61000-3-3:1995

8.2 Test Procedure


The equipment shall be tested under the conditions of **Clause 5**.

The total impedance of the test circuit, excluding the appliance under test, but including the internal impedance of the supply source, shall be equal to the reference impedance. The stability and tolerance of the reference impedance shall be adequate to ensure that the overall accuracy of $\pm 8\%$ is achieved during the whole assessment procedure.

8.3 Test Equipment Settings

- Line Voltage : 230 V
- Line Frequency : 50 Hz
- Measurement Delay : 10.0 seconds
- Pst Integration Time : 10 minutes
- Pst Integration Periods : 1
- Test Duration : 00:10:00 minutes

8.4 Test Setup



8.5 Test Result Of Voltage Fluctuation And Flicker Test

8.5.1 Test Data Of Voltage Fluctuation And Flicker


- FINAL TEST RESULT : **PASS**
- Temperature : 23°C
- Relative Humidity : 48%
- Test Date : May 08, 2002
- Test Mode : **Full Load**

- Urms = 229.7V
Freq = 49.984
Range: 5A
- Irms = 0.508A
Ipk = 2.151A
cf = 4.236
- P = 52.15W
Pap = 116.7VA
pf = 0.447

- Test - Time : 1 x 10min = 10min(100 %)


- LIN (Line Impedance Network) :Soft LIN 0.24 Ohm +j 0.15 Ohm N: 0.16 Ohm +j 0.10 Ohm

- Limits : 0.65 Plt : 0.65 Pst : 1.00
 dmax : 4.00 % dc : 3.00 %
 dtLim : 3.00 % dt>Lim: 200ms

Test Engineer : 
Bruce Huang

8.6 Photographs Of Harmonics Test, Voltage Fluctuation And Flicker Test

FRONT VIEW




REAR VIEW



9. Electrostatic Discharge Immunity Test (ESD)

- FINAL TEST RESULT : **PASS**
- Pass Performance Criteria : A
- Required performance criteria : B
- Basic Standard : IEC 61000-4-2:1995
- Product Standard : EN 55024:1998
- Level : 3 for air discharge
: 2 for contact discharge
- Test Voltage : $\pm 2 / \pm 4 / \pm 8$ KV for air discharge
: $\pm 2 / \pm 4$ KV for contact discharge
- Temperature : 25°C
- Relative Humidity : 50%
- Test Date : May 08, 2002
- Test Mode : **Full Load**
- Observation : Normal.

9.1 Test setup



The test setup consists of the test generator, EUT and auxiliary instrumentation necessary to perform DIRECT and INDIRECT application of discharges to the EUT as applicable, in the follow manner :

- a. CONTACT DISCHARGE to the conductive surfaces and to coupling plane;
- b. AIR DISCHARGE at insulating surfaces.

The preferred test method is that of type tests performed in laboratories and the only accepted method of demonstrating conformance with this standard. The EUT was arranged as closely as possible to arrangement in final installed conditions.



9.2 Test Setup for Tests Performed in Laboratory

A ground reference plane was provided on the floor of the test site. It was a metallic sheet (copper or aluminum) of 0.25 mm, minimum thickness; other metallic may be used but they shall have at least 0.65 mm thickness. In the SPORTON EMC LAB., we provided 1 mm thickness aluminum ground reference plane or 1 mm thickness stainless steel ground reference plane. The minimum size of the ground reference plane is 1 m x 1 m, the exact size depending on the dimensions of the EUT. It was connected to the protective grounding system.

The EUT was arranged and connected according to its functional requirements. A distance of 1m minimum was provided between the EUT and the wall of the lab. and any other metallic structure. In cases where this length exceeds the length necessary to apply the discharges to the selected points, the excess length shall, where possible, be placed non-inductively off the ground reference plane and shall not come closer than 0.2m to other conductive parts in the test setup.

Where the EUT is installed on a metal table, the table was connected to the reference plane via a cable with a 470k ohm resistor located at each end, to prevent a build-up of charge. The test setup was consist a wooden table, 0.8m high, standing on the ground reference plane. A HCP, 1.6 m x 0.8 m, was placed on the table. The EUT and cables was isolated from the HCP by an insulating support 0.5 mm thick. The VCP size, 0.5 m x 0.5 m.

9.3 ESD Test Procedure

- a. In the case of air discharge testing the climatic conditions shall be within the following ranges:
 - ambient temperature: 15°C to 35°C;
 - relative humidity : 30% to 60%;
 - atmospheric pressure : 68 KPa (680 mbar) to 106 KPa (1060 mbar).
- b. Test programs and software shall be chosen so as to exercise all normal modes of operation of the EUT.
The use of special exercising software is encouraged, but permitted only where it can be shown that the EUT is being comprehensively exercised.
- c. The test voltage shall be increased from the minimum to the selected test severity level, in order to determine any threshold of failure. The final severity level should not exceed the product specification value in order to avoid damage to the equipment.
- d. The test shall be performed with both air discharge and contact discharge. On preselected points at least 10 single discharges (in the most sensitive polarity) shall be applied on air discharge. On preselected points at least 25 single discharges (in the most sensitive polarity) shall be applied on contact discharge.
- e. For the time interval between successive single discharges an initial value of one second is recommended. Longer intervals may be necessary to determine whether a system failure has occurred.
- f. In the case of contact discharges, the tip of the discharge electrode shall touch the EUT before the discharge switch is operated.
- g. In the case of painted surface covering a conducting substrate, the following procedure shall be adopted :
 - If the coating is not declared to be an insulating coating by the equipment manufacturer, then the pointed tip of the generator shall penetrate the coating so as to make contact with the conducting substrate.
 - Coating declared as insulating by the manufacturer shall only be submitted to the air discharge.
 - The contact discharge test shall not be applied to such surfaces.
- h. In the case of air discharges, the round discharge tip of the discharge electrode shall be approached as fast as possible (without causing mechanical damage) to touch the EUT . After each discharge, the ESD generator (discharge electrode) shall be removed from the EUT. The generator is then retriggered for a new single discharge. This procedure shall be repeated until the discharges are completed. In the case of an air discharge test, the discharge switch, which is used for contact discharge, shall be closed.

9.4 Test Severity Levels

9.4.1 Contact Discharge

Level	Test Voltage (KV) of Contact discharge
1	± 2
2	± 4
3	± 6
4	± 8
X	Specified

Remark : "X" is an open level.

9.4.2 Air Discharge

Level	Test Voltage (KV) of Air Discharge
1	± 2
2	± 4
3	± 8
4	± 15
X	Specified

Remark : "X" is an open level.

9.5 Test Points

9.5.1 Test Result of Air Discharge

Test Point	Voltage	Tested No.
Case	$\pm 2 / \pm 4 / \pm 8$ KV	BY 10
LED	$\pm 2 / \pm 4 / \pm 8$ KV	BY 10

9.5.2 Test Result of Contact Discharge

Polarity	Voltage	Tested No.
Horizontal(At Front)	$\pm 2 / \pm 4$ KV	BY 25
Horizontal (At Left)	$\pm 2 / \pm 4$ KV	BY 25
Horizontal (At Right)	$\pm 2 / \pm 4$ KV	BY 25
Horizontal (At Rear)	$\pm 2 / \pm 4$ KV	BY 25
Vertical (At Front)	$\pm 2 / \pm 4$ KV	BY 25
Vertical (At Left)	$\pm 2 / \pm 4$ KV	BY 25
Vertical (At Right)	$\pm 2 / \pm 4$ KV	BY 25
Vertical (At Rear)	$\pm 2 / \pm 4$ KV	BY 25
Bracket	$\pm 2 / \pm 4$ KV	BY 25
Screw	$\pm 2 / \pm 4$ KV	BY 25

Test Engineer : Bruce
Bruce Huang

9.6 Photographs of Electrostatic Discharge Immunity Test

FRONT VIEW




REAR VIEW



10. Radio Frequency Electromagnetic Field Immunity Test (RS)

- FINAL TEST RESULT : **PASS**
- Pass Performance Criteria : A
- Required performance criteria : A
- Basic Standard : IEC 61000-4-3:1995
- Product Standard : EN 55024:1998
- Level : 2
- Frequency Range : 80-1000 MHz
- Field Strength : 3 V/m (Modulated 80% AM)
- Temperature : 26°C
- Relative Humidity : 49%
- Test Date : May 08, 2002
- Test Mode : **Full Load**
- Observation : Normal

10.1 Test setup



NOTE : The SPORTON 7m x 4m x 4m semichoice chamber is compliance with the sixteen points uniform field requirement as stated in IEC 1000-4-3 Section 6.2.

The procedure defined in this part requires the generation of electromagnetic fields within which the test sample is placed and its operation observed. To generate fields that are useful for simulation of actual (field) conditions may require significant antenna drive power and the resultant high field strength levels. To comply with local regulations and to prevent biological hazards to the testing personnel, it is recommended that these tests be carried out in a shielded enclosure or semichoice chamber.

10.2 Test Procedure

- a. The equipment to be tested is placed in the center of the enclosure on a wooden table. The equipment is then connected to power and signal leads according to pertinent installation instructions.
- b. The bilog antenna which is enabling the complete frequency range of 80-1000 MHz is placed 3m away from the equipment. The required field strength is determined by placing the field strength meter(s) on top of or directly alongside the equipment under test and monitoring the field strength meter via a remote field strength indicator outside the enclosure while adjusting the continuous-wave to the applicable antennae.
- c. The test is normally performed with the antenna facing the most sensitive side of the EUT. The polarization of the field generated by the biconical antenna necessitates testing each position twice, once with the antenna positioned vertically and again with the antenna positioned horizontally. The circular polarization of the field from the log-spiral antenna makes a change of position of the antenna unnecessary.
- d. At each of the above conditions, the frequency range is swept 80-1000 MHz, pausing to adjust the R.F. signal level or to switch oscillators and antenna. The rate of sweep is in the order of 1.5×10^{-3} decades/s. The sensitive frequencies or frequencies of dominant interest may be discretely analyzed.

10.3 Test Severity Levels

Frequency Band : 80-1000 MHz


Level	Test field strength (V/m)
1	1
2	3
3	10
X	Specified

Remark : "X" is an open class.

Test Engineer : Bruce
Bruce Huang

10.4 Photographs of Radio Frequency Electromagnetic Field Immunity Test

FRONT VIEW



REAR VIEW






11. Electrical Fast Transient/Burst Immunity Test (EFT/BURST)

- FINAL TEST RESULT : **PASS**
- Pass Performance Criteria : A
- Required performance criteria : B
- Basic Standard : IEC 61000-4-4:1995
- Product Standard : EN 55024:1998
- Level : on Power Supply -- 2
- Test Voltage : on Power Supply -- $\pm 0.5 / \pm 1.0$ KV
- Temperature : 23°C
- Relative Humidity : 48%
- Test Date : May 08, 2002
- Test Mode : **Full Load**
- Observation : Normal

11.1 Test setup



The EUT was placed on a ground reference plane and was insulated from it by an insulating support about 0.1m thick. If the EUT is table-top equipment, it was located approximately 0.8m above the GRP.. The GRP. was a metallic sheet (copper or aluminum) of 0.25 mm ,minimum thickness; other metallic may be used but they shall have at least 0.65 mm thickness. It shall project beyond the EUT by at least 0.1m on all sides and connected to the protective earth. In the SPORTON EMC LAB. we provided 1 mm thickness aluminum ground reference plane or 1 mm thickness stainless steel ground reference plane. The minimum size of the ground reference plane is 1 m x 1 m, the exact size depending on the dimensions of the EUT. It was connected to the protective grounding system. The EUT was arranged and connected according to its functional requirements. The minimum distance between the EUT and other conductive structures, except the GRP. beneath the EUT, was more than 0.5 m. Using the coupling clamp, the minimum distance between the coupling plates and all other conductive structures, except the GRP. beneath the EUT, was more than 0.5 m. The length of the signal and power lines between the coupling device and the EUT was 1m or less.

11.2 Test on Power Line

- a. The EFT/B-generator was located on the GRP.. The length from the EFT/B-generator to the EUT as not exceed 1 m.
- b. The EFT/B-generator provides the ability to apply the test voltage in a non-symmetrical condition to the power supply input terminals of the EUT.

11.3 Test on Communication Lines

- a. The coupling clamp is composed of a clamp unit for housing the cable (length more than 3 m), and was placed on the GRP..
- b. The coupling clamp provides the ability of coupling the fast transient/bursts to the cable under test.

11.4 Test Procedure

- a. In order to minimize the effect of environmental parameters on test results, the climatic conditions when test is carrying out shall comply with the following requirements:
 - ambient temperature: 15°C to 35°C;
 - relative humidity : 45% to 75%;
 - atmospheric pressure : 68 KPa (680 mbar) to 106 KPa (1060 mbar).
- b. In order to minimize the effect of environmental parameters on test results, the electromagnetic environment of the laboratory shall not influence the test results.
- c. The variety and diversity of equipment and systems to be tested make it difficult to establish general criteria for the evaluation of the effects of fast transients/bursts on equipment and systems.
- d. The test results may be classified on the basic of the operating conditions and the functional specification of the equipment under test, according to the following performance criteria :
 - Normal performance within the specification limits.
 - Temporary degradation or loss of function or performance which is self-recoverable.
 - Temporary degradation or loss of function or performance which requires operator intervention or system reset.
 - Degradation or loss of function which is not recoverable due to damage of equipment (components).




11.5 Test Severity Levels

The following test severity levels are recommended for the fast transient/burst test :

Open circuit output test voltage $\pm 10\%$		
Level	On Power Supply	On I/O signal, data and control line
1	0.5 KV	0.25 KV
2	1.0 KV	0.50 KV
3	2.0 KV	1.00 KV
4	4.0 KV	2.00 KV
X	Specified	Specified

Remark : " X " is an open level. The level is subject to negotiation between the user and the manufacturer or is specified by the manufacturer.

Test Engineer : 
Bruce Huang

11.6 Photographs of Electrical Fast Transient/Burst Immunity Test

FRONT VIEW



REAR VIEW



12. Surge Immunity Test

- FINAL TEST RESULT : **PASS**
- Pass performance Criteria : A
- Required performance criteria : B
- Basic Standard : IEC 61000-4-5:1995
- Product Standard : EN 55024:1998
- Input Voltage, Frequency : 230Vac, 50Hz
- Surge wave form (Tr/Th) : 1, 2/50 (8/20) μ s
- Level : 3
- Test Voltage : $\pm 1.0 / \pm 2.0$ KV
- Temperature : 23°C
- Relative Humidity : 48%
- Test Date : May 08, 2002
- Test Mode : **Full Load**
- Observation : Normal

12.1 Test Record

Voltage (KV)	Test Location	Polarity	Phase Angle				Test Result
			0°	90°	180°	270°	
1 KV	L - N	+	A	A	A	A	<u>PASS</u>
		—	A	A	A	A	<u>PASS</u>
2 KV	L - PE	+	A	A	A	A	<u>PASS</u>
		—	A	A	A	A	<u>PASS</u>
	N - PE	+	A	A	A	A	<u>PASS</u>
		—	A	A	A	A	<u>PASS</u>

⊕ Remark : PE = DC output GND

12.2 Test Level

Level	Open-circuit test voltage, $\pm 10\%$, KV
1	0.5
2	1.0
3	2.0
4	4.0
x	Specified
NOTE - x is an open class. This level can be specified in the product specification.	

12.3 Test Procedure

- a. Climatic conditions
The climatic conditions shall comply with the following requirements :
 - ambient temperature : 15 °C to 35 °C
 - relative humidity : 10 % to 75 %
 - atmospheric pressure : 86 kPa to 106 kPa (860 mbar to 1060 mbar)
- b. Electromagnetic conditions
The electromagnetic environment of the laboratory shall not influence the test results.
- c. The test shall be performed according the test plan that shall specify the test set-up with
 - generator and other equipment utilized;
 - test level (voltage/current);
 - generator source impedance;
 - internal or external generator trigger;
 - number of tests : at least five positive and five negative at the selected points;
 - repetition rate : maximum 1/min.
 - inputs and outputs to be tested;
 - representative operating conditions of the EUT;
 - sequence of application of the surge to the circuit;
 - phase angle in the case of a.c. power supply;
 - actual installation conditions, for example :
AC : neutral earthed,
DC : (+) or (-) earthed to simulated the actual earthing conditions.



- d. If not otherwise specified the surges have to be applied synchronized to the voltage phase at the zero-crossing and the peak value of the a.c. voltage wave (positive and negative).
- e. The surges have to be applied line to line and line(s) and earth. When testing line to earth, the test voltage has to be applied successively between each of the lines and earth, if there is no other specification.
- f. The test procedure shall also consider the non-linear current-voltage characteristics of the equipment under test. Therefore the test voltage has to be increased by steps up to the test level specified in the product standard or test plan.
- g. All lower levels including the selected test level shall be satisfied. For testing the secondary protection, the output voltage of the generator shall be increased up to the worstcase voltage breakdown level (let-through level) of the primary protection.
- h. If the actual operating signal sources are not available, they may be simulated. Under no circumstances may the test level exceed the product specification. The test shall be carried out according to a test plan.
- i. To find all critical points of the duty cycle of the equipment, a sufficient number of positive and negative test pulses shall be applied. For acceptance test a previously unstressed equipment shall be used to the protection devices shall be replaced.

12.4 Operating Condition

Full system

Test Engineer : *Bruce*
Bruce Huang

12.5 Photographs of Surge Immunity Test

FRONT VIEW



REAR VIEW



13. Conducted Disturbances Induced by Radio-Frequency Field Immunity Test (CS)

- FINAL TEST RESULT : **PASS**
- Pass performance Criteria : A
- Required performance criteria : A
- Basic Standard : IEC 61000-4-6:1996
- Product Standard : EN 55024 :1998
- Input Voltage, Frequency : AC 230V, 50Hz
- Level : 2
- Test Voltage : 3 V/rms (Modulated, 1KHz, 80%, AM)
- Frequency Range : 0.15 MHz to 80 MHz
- Dwell time : 2.9 seconds
- Frequency step size : 1 %
- Coupling mode : CDN-M3
- Temperature : 24°C
- Relative Humidity : 50%
- Test Date : May 08, 2002
- Test Mode : **Full Load**
- Observation : Normal

13.1 Test Level

Level	Voltage Level (EMF),
1	1 V
2	3 V
3	10 V
x	Specified
NOTE - x is an open class. This level can be specified in the product specification.	

13.2 Operating Condition

Full system




13.3 Test Procedure

- a. The EUT shall be operated within its intended climatic conditions. The temperature and relative humidity should be recorded.
- b. This test method test can be performed without using a sell shielded enclosure. This is because the disturbance levels applied and the geometry of the setups are not likely to radiated a high amount of energy, especially at the lower frequencies. If under certain circumstances the radiated energy is too high, a shielded enclosure has to be used.
- c. The test shall be performed with the test generator connected to each of the coupling and decoupling devices in turn while the other non-excited RF-input ports of the coupling devices are terminated by a 50 ohm load resistor.
- d. Filters shall be used to prevent (higher order or sub-) harmonics form disturbing the EUT. A High-Pass Filter. 100KHz, (HPF) may be required with the test generator. The band stop characteristics of the Low-Pass Filters (LPF) shall be sufficient to suppress the harmonics down to the immunity level required within that band. These filters shall be inserted with the test generator before setting the test level.
- e. The frequency range is swept from 150 KHz to 230 MHz, using the signal levels established during the setting process, and with the disturbance signal 80% amplitude modulated with a 1KHz sinewave, pausing to adjust the RF-signal level or to switch coupling devices as necessary. The rate of sweep shall no exceed 1.5×10^{-3} decades/s. Where the frequency is swept incrementally, the step size shall no exceed 1% of the start and thereafter 1% of the preceding frequency value.
- f. The dwell time at each frequency shall not be less than the time necessary for the EUT to be exercised, and able to respond. Sensitive frequencies e.g. clock frequency(ies) and harmonics or frequencies of dominant interest shall be analyzed separately.
- g. An alternative test procedure may be adopted, wherein the frequency range is swept incrementally, with a step size not exceeding 4% of the start ad thereafter 4% of the preceding frequency value. The test level should be at least twice the value of the specified test level.
- h. In cases of dispute, the test procedure using a step size not exceeding 1% of the start and thereafter 1% of preceding frequency value shall take precedence.
- i. Attempts should be made to fully exercise the EUT during testing, and to fully interrogate all exercise modes selected for susceptibility.
- j. The use of special exercising programs is recommended.
- k. Testing shall be performed according to a Test Plan, which shall be included in the test report.
- l. It may be necessary to carry out some investigatory testing in order to establish some aspects of the test plan.


Test Engineer : Bruce
Bruce Huang

13.4 Photographs of Conducted Disturbances Induced by Radio-Frequency Field Immunity Test

FRONT VIEW



REAR VIEW




14. Power Frequency Magnetic Field immunity tests

- FINAL TEST RESULT : **PASS**
- Pass performance Criteria : A
- Required performance criteria : A
- Basic Standard : IEC 61000-4-8:1993
- Product Standard : EN 55024 :1998
- Input Voltage, Frequency : AC 230V, 50Hz
- Temperature : 23°C
- Relative Humidity : 49%
- Test Date : May 08, 2002
- Test Mode : **Full Load**
- Observation : Normal

14.1 Test Record

Power Frequency Magnetic Field	Testing duration	Coil Orientation	Results	Remark
50Hz, 1A/m	1.0 Min	X-axis	Pass	Normal
50Hz, 1A/m	1.0 Min	Y-axis	Pass	Normal
50Hz, 1A/m	1.0 Min	Z-axis	Pass	Normal

14.2 Test Setup



- | | |
|----------------------------|---------------------------------|
| GRP : Ground plane | C1 : Power supply circuit |
| A : Safety earth | C2 : Signal circuit |
| S : Insulating support | L : Communication line |
| EUT : Equipment under test | B : To power supply source |
| Lc : Induction coil | D : To signal source, simulator |
| E : Earth terminal | G : To the test generator |

Test Engineer : Bruce
Bruce Huang

14.3 Photographs of Power Frequency Magnetic Field immunity tests

FRONT VIEW



REAR VIEW



15. Voltage Dips and Voltage Interruption Immunity Tests

- FINAL TEST RESULT : **PASS**
- Pass performance Criteria : C for voltage interruption, A for voltage dips
- Required performance criteria : C for voltage interruption, B/C for voltage dips
- Basic Standard : IEC 61000-4-11:1994
- Product Standard : EN 55024:1998
- Input Voltage, Frequency : AC 230V, 50Hz
- Temperature : 23°C
- Relative Humidity : 49%
- Test Date : May 08, 2002
- Test Mode : **Full Load**

15.1 Test Record of Voltage Interruption

Voltage (V)	Phase Angle		% Reduction	periods (s)	Observation
	0 °	180 °			
230	C	C	>95%	250	<i>When testing, the power of EUT reset automatically.</i>

15.2 Test Record of Voltage Dips

Voltage (V)	Phase Angle		% Reduction	periods (s)	Observation
	0 °	180 °			
230	A	A	30	25	<i>Normal</i>
230	A	A	>95 %	0.5	<i>Normal</i>

15.3 Testing Requirement and Procedure

The test was based on IEC 61000-4-11:1994

15.4 Test Conditions

1. Source voltage and frequency : 230V / 50Hz, Single phase.
2. Test of interval : 10 sec.
3. Level and duration : Sequency of 3 dips/interrupts.
4. Voltage rise (and fall) time : 1 ~ 5 μ s.
5. Test severity :

Voltage dip and Interrupt reduction (%)	Test Duration (ms)
30	500
60	100
100	10
100	80
100	5000


15.5 Operating Condition

Full system

Test Engineer : *Bruce*
Bruce Huang

15.6 Photographs of Voltage Dips and Voltage Interruption Immunity Tests

FRONT VIEW



REAR VIEW



16. Antenna Factor & Cable Loss

Frequency (MHz)	Antenna Factor (dB)	Cable Loss (dB)
30	17.0	0.8
35	16.0	0.8
40	13.5	0.9
45	9.9	0.9
50	7.4	0.9
55	6.8	1.0
60	6.3	1.0
65	6.3	1.1
70	6.3	1.2
75	6.9	1.5
80	7.5	1.2
85	8.9	1.2
90	10.2	1.3
95	11.0	1.3
100	11.8	1.3
110	11.9	1.4
120	12.0	1.4
130	11.9	1.4
140	11.4	1.5
150	10.9	1.6
160	10.3	1.6
170	9.6	1.7
180	9.5	1.8
190	9.7	1.8
200	9.9	1.9
220	11.2	2.1
240	12.5	2.1
260	13.4	2.0
280	13.8	2.2
300	14.2	2.2
320	14.5	2.3
340	14.8	2.4
360	15.2	2.5
380	15.5	2.6
400	15.8	2.7
450	16.8	2.9
500	17.9	3.0
550	18.9	3.2
600	19.7	3.3
650	19.5	3.4
700	19.2	3.6
750	19.4	3.8
800	19.7	4.1
850	20.4	4.3
900	21.1	4.5
950	22.0	4.6
1000	22.9	4.6

LKOP7

17. List of Measuring Equipment Used

< EMI >

Instrument	Manufacturer	Model No.	Serial No.	Characteristics	Calibration Date	Remark
EMC Receiver (site 2)	HP	8591EM	3536A00672	9 KHz – 1.8 GHz	Aug. 28, 2001	Conduction
LISN (Support Unit) (site 2)	AFJ	AFJ LT32	32030012050	50 ohm / 50 uH	May 29, 2001	Conduction
LISN (EUT) (site 2)	Telemeter	NNB-2/16Z	98081	50 ohm / 50 uH	Dec. 17, 2001	Conduction
Spectrum Analyzer (site 7)	ADVANTEST	R3261C	71720606	9KHz – 2.6GHz	Apr. 10, 2002	Radiation
Amplifier (Site 7)	HP	8447D	2944A09068	100KHz –1.3GHz	Oct. 03, 2001	Radiation
Bilog Antenna (Site 7)	CHASE	CBL6112A	2287	30MHz -2GHz	Feb. 08, 2002	Radiation
Half-wave dipole antenna (Site 7)	EMCO	3121C	9705-1285	28 M - 1GHz	May 17, 2001	Radiation
Antenna Mast (site 7)	EMCO	2075	9806-2160	1MHz – 4MHz	N/A	Radiation
Turn Table (site 7)	EMCO	2080	9806-2070	0° ~ 360°	N/A	Radiation
Controller (site 7)	EMCO	2090	9804-1328	N/A	N/A	Radiation

※ Calibration Interval of instruments listed above is one year.

< EMS >

Instrument	Manufacturer	Model No.	Characteristics	Calibration Date	Remark
ESD Simulator	KEYTEK	MZ-15/EC	0 KV - 15 KV	Apr. 25, 2002	ESD
Mini Zap	KEYTEK	TPC-2	0 KV - 15 KV	Apr. 25, 2002	ESD
Amplifier	AR	100W 1000M3	80 MHz - 1 GHz	N/A	RS
Isotropic Field Probe	AR	FP3000A	10 KHz - 1 GHz	Jun. 18, 2001	RS
IEEE-488 Interface	AR	CP3000	N/A	N/A	RS
System Interface	EMC Automation	200	HP-IB INTERFACE	N/A	RS
Power Meter	EMC Automation	438A	100 KHz -4.2 GHz	N/A	RS
Video Camera controller	EMC Automation	VCC-01	N/A	N/A	RS
Signal Generator	HP	8648A	100 KHz - 1 GHz	Sep. 08, 2001	RS
Signal Generator	R&S	SMX	100 KHz - 1 GHz	Nov. 05, 2001	RS
Antenna	CHASE	CBL6121A	26 MHz - 1 GHz	Jun. 11, 2001	RS
Amplifier	AR	75W 75A220	25MHz - 300MHz	Jun. 13, 2001	RS
EFT Generator	KEYTEK	CE-40	0 KV - 4.4 KV	Sep. 05, 2001	EFT
Harmonic/Flicker Test System	HP	6843A	4800VA 90A / 48A PEAK	Nov. 13, 2001	Harmonics, Flicker
Combination Wave Generator	EMC PARTNER AG Switzerland	MIG0603IN2	6 KV, 3 KA	Jun. 26, 2001	SURGE
Conducted Immunity Test System	FRANKONIA	CIT-10/W	100KHz ~ 266MHz	Jun. 09, 2001	CS
Magnetic field Antenna	EMC PARTNER	MF-1000	0.5 up to 150A / m	Jun. 26, 2001	Magnetic
EMC Immunity Tester	EMC PARTNER AG Switzerland	TRANSIENT 1000	0 ~ 260 rms, 16A	Jun. 26, 2001	DIP



18. Notice for Class A Product

This Notice is for class A product only. If the Equipment under Test is a class B product, this notice should be disregarded.

Class A ITE is a category of all other ITE which satisfies the class A ITE limits but not the class B ITE limits. Such equipment should not be restricted in its sale but the following warning shall be included in the instructions for use:

Warning

This is a class A product. In a domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

19. Declaration of Conformity and the CE Mark

There are three possible procedures pertaining to the declaration of conformity :

19.1 Conformity Testing and Declaration of Conformity by the Manufacturer or His Authorized Representative Established within the Community or by an Importer.

- Article 10 (1) of the EMC Directive,
- § 3 (1) no. 2a of the EMC Act.

19.2 Declaration of Conformity Issued by the Manufacturer or His Authorized Representative Established within the Community or by an Importer Following Testing of the Product and Issued of an EC certificate of conformity by a competent body.

- Article 10 (2) of the EMC Directive,
- § 3 (1) no. 2b of the EMC Act.

19.3 Declaration of Conformity Issued by the Manufacturer or His Authorized Representative Established within the Community or by an Importer Following Testing and Certification of the Product by a Notified Body.

- Article 10 (5) of the EMC Directive,
- § 3 (1) no. 2b of the EMC Act (radio transmitting installations).

19.4 Specimen For The CE Marking Of Electrical / Electronical Equipment

The components of the CE marking shall have substantially the same vertical dimension, which may not be less than 5 mm.

